

Memo No:- 211

Date:- 28/04/2022

Certificate
No: TC-9491

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : MEW/00128/4/2022 / Private	Sample Details	Date & Time
Sender : Noman Ahmed11838	Collected By	Noman Ahmed
Location : , ALIF INTERNATIONAL SCHOOL	Collection Date	27/04/2022 at 10:38
Sample Description : Drinking Water	Received at lab	27/04/2022 at 11:32
Latitude / Longitude : 77.009389 / 28.089697	Analysis Start Date	27/04/2022
	Analysis End Date	27/04/2022
	Sample Quantity	1 Litter

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	363	500 mg/l.	2000 mg/l.	APHA2540 C; 2017
2	Total Hardness as CaCO ₃	225	200 mg/l.	600 mg/l.	APHA2340 C; 2017
3	Calcium as Ca	35	75 mg/l.	200 mg/l.	APHA3500-Ca B; 2017
4	Magnesium as Mg	33	30 mg/l.	100 mg/l.	APHA3500 Mg B; 2017
5	Iron as Fe	<0.1	1.0 mg/l.	1.0 mg/l.	APHA3500-Fe B; 2017
6	Chloride as Cl	211	250 mg/l.	1000 mg/l.	APHA4500 Cl-B; 2017
7	Sulphate as So ₄	94	200 mg/l.	400 mg/l.	APHA4500-So ₄ -E
8	Fluoride as F	0.12	1.0 mg/l.	1.5 mg/l.	APHA 4500-D; 2017
9	Nitrate as No ₃	5.3	45 mg/l.	45 mg/l.	APHA 4500-NO ₃ - D
10	pH @ 25°C	7.64	6.5 - 8.5	6.5 - 8.5	APHA4500-H+ B; 2017
11	Total Alkalinity	254	200 mg/l.	600 mg/l.	APHA 2320 B; 2017
12	Color	5	5 Hazen Units	15 Hazen Units	APHA 2120-B
13	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
14	Turbidity	<0.5	1 NTU	5 NTU	APHA2130 B; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED MEWAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

SH. TAHIR HUSSAIN ,CHEMIST
DISTRICT WATER TESTING LABORATORY MEWAT
email:-chemist.mewat@phedharyana.gov.in

-----END OF TEST REPORT-----